

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

November 19, 2013

WADE HYDROMAX TYLER PIPE CRAIG AKIN 11910 CR 492 TYLER TX 75706

Re: Description: SIPHONIC ROOF DRAIN

Manufacturer: WADE HYDROMAX

Product Name: WADE HYDROMAX SIPHONIC ROOF DRAIN

Model Number(s): WH300, WH400, WH500, WH600, WH301, WH401, WH501, WH601, WH300PG AND

WH400PG

Product File No: 20130352

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.36 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2018.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The roof drains must comply with ASME A112.6.9-2005.
- The design and installation of the siphonic roof drain must be in accord with ASPE technical Standard 45.
- All materials must comply with ASPE Technical Standard 45.
- Each siphonic roof drain and gutter drain shall be permanently marked at the dome, bodies, and baffle plates
 with the manufacturer name or trademark. The baffle plate and drain body shall also be marked with the baffle
 model number, resistance value, K, and words "REPLACE MISSING BAFFLE WITH MODEL ______." The
 marking shall be located at a location visible after installation.
- Plans and specification for siphonic roof drain systems must be approved by this Department prior to installation of the system.
- Maintenance of the roof shall conform to ASPE Technical Standard 45

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail

SBD-10564-E (N.10/97) File Ref: 13035201.DOC